

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

No students were present at the facility during the time of inspection.

Room #331 is currently under renovation/ construction due to an overhead leak.

Email Address(es): amontero@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Provide missing ceiling tiles for rooms 215, 243, 234, 347, and 334.

Repair hole in base board by door 231A and underneath windows of cafeteria.

Replace water stained ceiling tiles in rooms 215 and 339.

Replace inoperable light bulbs in rooms 214, 212, 247, 233, and 307.

Provide light fixture covers for rooms 233, 243, and 339.

Repair hanging vent coverings located in room 239.

Replace cracked electrical outlet located under the teachers desk in room 307.

Replace cracked floor tile by exit door in room 302.

Repair peeled away floor board by exit door in room 307.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Inspection Conducted By: Abigail DeFabio (027431)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: William Lehman Elem.
Date: 7/8/2020

Inspector Signature:

Handwritten signature of the inspector, Abigail DeFabio.

Client Signature:

Handwritten signature of the client, William H. Lehman.